

Building Code Board of Appeals

Agenda

**May 2, 2024
City Hall, Spruce Room
749 Main Street
6:30 PM**

Members of the public are welcome to attend and give comments remotely; however, the in-person meeting may continue even if technology issues prevent remote participation.

- Call in: + 1 (719) 359-4580
Meeting ID: 329 717 5559
Passcode: 576173107
- Zoom Login: <https://louisvilleco.zoom.us/j/3297175559>
- Zoom Password: "BCBOA0320"
- You can log in via your computer. Please visit the City's website here to link to the meeting: www.louisvilleco.gov/bcboa

The Board will accommodate public comments during the meeting. Anyone may also email comments to the Board prior to the meeting at Building@LouisvilleCO.gov.

1. Call to Order
2. Roll Call
3. Approval of Agenda
4. Approval of Meeting Minutes from 3/20/24 and 4/18/24
5. Public Comments on Items Not on the Agenda
6. Discussion and voting of changes to the proposed 2021 IECC ordinance
7. Discussion Items for Next Meeting
8. Adjourn

Persons planning to attend the meeting who need sign language interpretation, translation services, assisted listening systems, Braille, taped material, or special transportation, should contact the City Clerk's Office at 303.335-4536 or MeredythM@LouisvilleCO.gov. A forty-eight-hour notice is requested.

Si requiere una copia en español de esta publicación o necesita un intérprete durante la reunión, por favor llame a la Ciudad al 303.335.4536 o 303.335.4574.

Building Code Board of Appeals

Meeting Minutes

**March 20, 2024
City Hall, Spruce Room
749 Main Street
6:30pm**

Call to Order – Chairperson Matt Berry called the meeting to order at 6:37pm.

Roll Call was taken and the following members were present:

Board Members Present:

Matt Berry
Christian Dino
Mason Gatto
Peter Geise

Board Members Absent:

Steve Knapp

Staff Members Present:

Chad Root, Chief Building Official
Jenny Lane, Permit Technician

Approval of Agenda –

The agenda was approved by all members.

Approval of Meeting Minutes –

Meeting minutes for May 18, 2023 were approved by all members.

Election of Officers -

The Board elected officers. Christian Dino as Chair and Mason Gatto as Vice-Chair.

Discussion of adoption of 2024 ICC codes -

Chad explained that typically the Building Department skips a year of ICC codes. He further explained that the 2021 code has new code that has been removed from the 2024 code. Louisville is working with all of northern Colorado to adopt the 2024 codes sometime in the summer of 2024 to City Council and keep the amendments the same or similar between municipalities. The 2023 NEC Electric code has already been adopted by the State.

IECC and IRC of 2024 edition is not published yet. Staff will begin reviewing 2024 suite of codes. IEBC 2024 adoption and “change of use” in regards to the IECC code.

State energy office requiring 2021 IECC and cannot go back to be less than the state requirements, only affecting municipalities that have a building dept, others are exempt from meeting the code.

The Board discussed the differences of 2021 IECC code and vs. adopting the 2024 IECC.

Chad explained the draft into one version compiled of previous 2021 IECC amendments. Met with contractor and homeowners over issues with current energy code requirements and developing new requirements including heat pump parameters of what is a cold climate heat pump; allows gas for RTUs; heat recovery systems.

2024: residential battery systems and storage; energy companies will start charging higher amounts during peak times. Gas and hydrogen infusion systems.

Possible amendment on battery packs, due to toxicity and fire hazard cannot be inside the house.

The Board discussed the WUI code and fire sprinklers and that if the City brought back fire sprinklers that the WUI code would not be as necessary. Some options instead of fire sprinklers would be screens on attic vents; hardie siding; fire rated windows.

Public Comments –

1. Chad read email from Andy Johnson regarding HERS ratings differences between HERS 48 and 47 and appendix RC. Appendix RC requires HERS of 47 before renewals. The cost difference between HERS of 48 and 47 is significant. He explained models he ran for 47,48, 49 and the cost difference in the tens of thousands and cost between 47 and 48 is known to energy raters. He believes this is financial segregation for affordability in building a house. He recommends a HERS of 50 and cleaning up the energy code.
2. Chad explained that City Council decided the day before the BCBOA meeting that they would like the Board to provide guidance on recommendation for 2021 energy code revisions. The Board decided that they need more time to review the changes. The Board would like to compare the original documents used to develop the initial ordinance compared to new documents.

Discussion Items for Next Meeting -

Housekeeping Informational Items (no vote/discussion needed):

- i. 2024 Open Government Pamphlet
- ii. Rules of Procedure

Approval of Posting locations for Agendas –

The Board approved the posting locations for agendas.

Next meeting on April 3, 2024

Adjourn – The meeting was adjourned at 8:53pm.

Building Code Board of Appeals

Meeting Minutes

**April 18, 2024
City Hall, Spruce Room
749 Main Street
6:30pm**

Call to Order – Chairperson Christian Dino called the meeting to order at 6:37pm.

Roll Call was taken and the following members were present:

Board Members Present:

Matt Berry – via Zoom
Christian Dino
Mason Gatto
Peter Geise

Board Members Absent:

Steve Knapp

Staff Members Present:

Chad Root, Chief Building Official
Jenny Lane, Permit Technician

Quasi-Judicial Training –

City Attorney Kelly presented the annual quasi-judicial training to the Board.

Approval of Agenda –

The agenda was approved by all members.

Public Comments on Items Not on the Agenda –

None

Continued from March 7, 2024 Meeting –

A. Informational Items (no action)

1. 2024 Open Government Pamphlet
2. Rules of Procedure

2021 Energy Code Revisions –

Root discussed the current issue that commercial contractors are waiting on a decision from the Board regarding allowing the use of gas equipment.

The **Board** discussed that Chairman, Christian Dino would email City Council to let them know they will prepare changes to the proposed ordinance at the next BCBOA Board meeting and will share those results with City Council.

Discussion Items for Next Meeting –

Discuss and prepare changes to IECC ordinance as proposed by City Council

Next meeting on May 2, 2024

Adjourn – The meeting was adjourned at 8:45pm.

ORDINANCE NO. _____, SERIES 2024

AN ORDINANCE AMENDING CHAPTER 15.18.030 OF THE LOUISVILLE MUNICIPAL CODE CONCERNING THE 2021 INTERNATIONAL ENERGY CONSERVATION CODE

WHEREAS, the City Council has adopted from time-to-time certain building and construction standards; and

WHEREAS, it is deemed to be in the interest of the public health, safety and general welfare to adopt by reference thereto the 2021 edition of the International Energy Conservation Code with amendments and additions to such code; and

WHEREAS, the City Council adopted Ordinance No. 1816, Series 2021 and Ordinance No. 1845, Series 2022, which included the adoption of Appendix RC to the 2021 edition of the International Energy Conservation Code, and provisions for electric space and water heating provisions for commercial development, and a new Appendix PT setting standards for energy ratings for certain commercial development; and

WHEREAS, following additional research and public input on the provisions adopted in Ordinance No. 1816, Series 2021 and Ordinance No. 1845, Series 2022, the City desires to make certain amendments to such codes to ensure the feasibility of implementation of the codes; and

WHEREAS, the City of Louisville remains committed to its adopted goals to reduce energy consumption, increase clean energy sources, and support the transition to a low-carbon community as outlined in the Sustainability Action Plan and Resolution 25, Series 2019, A Resolution Setting Clean Energy and Carbon Reduction Goals; and

WHEREAS, reducing building energy consumption is an effective strategy to reduce community-wide energy consumption and increase long-term cost savings for businesses; and

WHEREAS, the City Council is committed to environmental, economic and social sustainability, ensuring the International Energy Conservation Code is attainable for current and future business owners and tenants, supporting affordable housing and local businesses development.

WHEREAS, the City Council, after proper notice as required by law, has held a public hearing on this ordinance providing for amendments to said codes; and

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF LOUISVILLE, COLORADO:

Section 15.18.030 of the Louisville Municipal Code, concerning amendments and deletions to the 2021 International Energy Conservation Code, is hereby amended as follows (deleted text in ~~strikethrough~~ and new text underlined):

1. *Section C101.1 Title*, is amended to insert "the City of Louisville" so the section will read:

C101.1 Title. These regulations shall be known as the Energy Conservation Code of the City of Louisville, and shall be cited as such. It is referred to herein as "this code."

2. *Section C103.2 Information on construction documents*, is hereby amended to read as follows:

C103.2 Information on construction documents. Construction documents shall be drawn to scale upon suitable material. Electronic media documented are permitted to be submitted when *approved* by the *code official*. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the building, systems and equipment herein governed. Details shall include the following as applicable:

1. Energy compliance path.
2. Insulation materials and their *R*-values
3. Fenestration *U*-factor and solar heat gain coefficients (SHGCs).
4. Area-weighted *U*-factor and solar heat gain coefficient (SHGC) calculations.
5. Mechanical system design criteria.
6. Mechanical and service water heating systems and equipment types, sizes, fuel source and efficiencies.
7. Economizer description.
8. Equipment and system controls.
9. Fan motor horsepower (hp) and controls.
10. Duct sealing, duct and pipe insulation and location.
11. Lighting fixture schedule with wattage and control narrative.
12. Location and *daylight* zones on floor plans.
13. Air barrier and air sealing details, including the location of the air barrier.
14. Location of pathways for routing of raceways or cable from the solar ready zone to the electrical service panel.

3. *Section C202 General Definitions*, is hereby amended by adding, in alphabetical order, the following definitions:

All-Electric Building: A building that contains no combustion equipment, ~~or piping or plumbing for combustion equipment, installed within the building or building site.~~

Combustion Equipment: Any equipment or appliance used for space heating, service water heating, cooking, clothes drying and/or lighting that uses fuel gas or fuel oil.

Electric Vehicle (EV): A vehicle registered for on road use, primarily powered by an electric motor that draws current from a rechargeable storage source that is charged by being plugged into an electrical current source.

Electric Vehicle Supply Equipment (EVSE): The electrical conductors and associated equipment external to the electric vehicle that provide a connection between the premises wiring and the electric vehicle to provide electric vehicle charging.

Electric Vehicle Capable Space: A designated parking space that is provided with conduit sized and rated for a minimum 40 amp, 208/240 Volt dedicated branch circuit and shall be no less than 1" in size. Conduit must be continuous from the future or existing electrical panelboard or switchboard location(s) and end at a junction box or receptacle located within close proximity of the parking space. The electrical panel serving the parking space shall have sufficient capacity and physical space for a dual pole, 40 amp breaker. The conduit shall be sealed at the junction or outlet box that is capped off, with the conduit sealed and the cap labeled as "For future electric vehicle charging".

Electric Vehicle Ready Space: A designated parking space that is provided with a dedicated branch circuit with wiring capable of supporting a minimum 40-ampere, 208/240 Volt circuit that terminates at a receptacle, plug, junction box, or an installed electric vehicle supply equipment within close proximity of the parking space. There shall be adequate reserved space in an electrical panelboard or switchboard to meet the electric vehicle requirements.

Electric Vehicle Supply Equipment (EVSE) Installed Space: A designated parking space with dedicated electric vehicle supply equipment capable of supplying a minimum 40-amp, dedicated circuit rated at 208/240 Volt from a building electrical panelboard.

Emergency Power System: A source of automatic electric power of a required capacity and duration to operate required life safety, fire alarm, detection, and ventilation systems in the event of a failure of the primary power. Emergency power systems are those required for electrical loads where interruption of the primary power could result in loss of human life or serious injuries.

Energy Use Intensity (EUI): The annual building site energy use per square foot of gross floor area in units of kBtu/sq ft.

Residential Building: For this code, includes detached one- and two-family dwellings and multiple single-family dwellings (townhouses) R-3 and R-4 buildings three stories or less in height above grade plane.

Standby Power System: A source of automatic electric power of a required capacity and duration to operate required building, hazardous materials or ventilation systems in the event of a failure of the primary power. Standby power systems are those required for electrical loads where interruption of the primary power could create hazards or hamper rescue or fire-fighting operations.

Tenant Finish: The first tenant occupying a space(s) in a core and shell. Multiple tenants may be considered as a tenant finish until the entire space within the core and shell has had a tenant. Once a space within a core and shell has been occupied it becomes an existing building.

4. C401.2. Commercial buildings shall comply with ~~Section C401.2.1~~ one of the following, as applicable

C401.2.1 Performance targets. New commercial building types included in the scope of Appendix PT shall comply with Appendix PT and Sections C403.2.4 and C404.10.

C401.2.2 Core and shell. Core and shell buildings shall comply with the provisions of Section C402.1.3 through C402.5. When mechanical systems are installed, core and shell buildings shall also meet the provisions in C403.2.4, C404.10, and Section C408.

C401.2.2.1 Core and shell buildings shall submit a letter of agreement to the City stating the tenant spaces included in the scope of Appendix PT shall meet the EUI target established in Table PT103 and shall include these requirements in their lease or purchase agreements.

C401.2.3 Tenant finish. Tenant finishes included in the scope of Appendix PT shall comply with Appendix PT and C403.2.4 and C404.10. All other tenant finishes shall comply with the Prescriptive Compliance option, which requires compliance with Sections C401.3, C401.4, C402 through C406, and C408.

C401.2.4 Other commercial building types. Commercial building types not included above, including additions, shall comply with the Prescriptive Compliance option, which requires compliance with Sections C401.3, C401.4, C402 through C406, and C408.

Exception: ~~Additions, alterations,~~ Alterations, repairs, and changes of occupancy to existing buildings complying with Chapter 5.

5. *Section C401.2.1 International Energy Conservation Code*, is hereby deleted and replaced to read as follows:

C401.2.1 International Energy Conservation Code

Commercial buildings shall be built all-electric unless the fuel gas options of C403.3.2 and the additional electric infrastructure requirements of C405.14 are met. All buildings must comply with the following:

City of Louisville's Prescriptive Compliance. The Prescriptive Compliance option requires compliance with Sections C401.3, C401.4, C402 through C406, and Section C408.

Core and shell buildings shall be required to comply with the provisions of Section C402.1.3 through C402.5 of the 2021 International Energy Conservation Code.

6. *Section C401.2.2 ASHRAE 90.1*, is hereby deleted in its entirety.
7. A new *Section C401.4 Mandatory Requirements for Commercial Buildings*, is hereby added to read as follows:

C401.4 Mandatory Requirements for Commercial Buildings. Commercial buildings must comply with Table C401.4.

Table C401.4 (Mandatory)
Requirements for Commercial Buildings

Title	IECC Section
Air leakage	C402.5
Calculation of heating and cooling loads	C403.1.1
Data centers	C403.1.2
System Design	C403.2
Heating and cooling equipment efficiency	C403.3
Heating and cooling system controls	C403.4, except C403.4.3, C403.4.4, C403.4.5
Economizer fault detection and diagnostics	C403.5.5
Ventilation and exhaust systems	C403.7, except C403.7.4.1
Fan and fan controls	C403.8, except C403.8.6
Large diameter ceiling fans	C403.9
Refrigeration equipment performance	C403.11, except C403.11.3
Construction of HVAC system elements	C403.12

Mechanical systems located outside of the building thermal envelope	C403.13
Service water heating	C404
Electrical power and lighting systems	C405, except C405.3
Maintenance information and system commissioning	C408

8. *Table C402.1.3 Opaque Thermal Envelope Insulation Component Minimum Requirements, R-Value Method*, is hereby deleted and replaced with the following:

Table C402.1.3 (Mandatory)
Opaque Thermal Envelope Insulation Component of an Average Minimum Requirements, R-Value Method in following locations:

Roof C402.2.1	
Insulation entirely above roof deck	R-49
Metal buildings ^a	R-21 + R-11 LS
Attic and other	R-49
Walls. Above grade C402.2.2	
Mass ^d	R-21
Metal buildings	R-21 + <u>R-10ci</u>
Metal framed	R-21+ <u>R-10ci</u>
Wood framed and other	R-21
Walls, Below grade C402.2.5	
Below-grade wall ^b	R-10
Floors C402.2.3	
Mass ^c	R-21
Joist/framing	R-38
Slab-on-grade floors C402.2.4	
Unheated	R-20 for 24" below
Heated ^e	R-15 for 36" below + R-5 full slab

For SI: 1 inch = 25.4 mm, 1 pound per square foot = 4.88 kg/m², 1 pound per cubic foot = 16 kg/m³.

NR = No Requirement, LS = Liner System.

- a. Where using R-value compliance method, a thermal spacer block shall be provided,
- b. Where heated slabs are below grade, below-grade walls shall comply with the exterior insulation requirements for heated slabs.
- c. "Mass floors" shall be in accordance with Section C402.2.3.
- d. "Mass walls" shall be in accordance with Section C402.2.2.
- e. The first value is for perimeter insulation and the second value is for full, under-slab insulation.

9. *Section C402.1.4 Assembly U-factor, C-factor or F-factor-based method*, is hereby deleted in its entirety.

10. *Section C402.1.5 Component performance alternative*, is hereby deleted in its entirety.

11. *Table C402.4 Building Envelope Fenestration Maximum U-Factor and SHGC Requirements*, is hereby deleted and replaced with the following:

Table C402.4
Building Envelope Fenestration

Vertical Fenestration	
Maximum U-Factor	0.45
Maximum SHGC	0.33
Maximum Air leakage rate for all fenestration except curtain walls and storefront glazing	.20 cfm/ft ²
Maximum air leakage rate for curtain walls and storefront glazing	.06 cfm/ft
Skylights	
Maximum U-Factor	0.50
Maximum SHGC	0.40
Maximum Air leakage rate	.20 cfm/ft ²

~~12. *Section C402.4.1 Maximum area*, is hereby deleted and replaced with the following:~~

~~C402.4.1 Minimum area of natural lighting. Not less than eight percent of the floor area shall be glazed.~~

12. *Section C402.4.1.2* is deleted and replaced with the following:

C402.4.1 Minimum area of natural lighting. Not less than 8% of wall area for warehouses; and industrial shall be glazed.

~~13. *Section C402.4.2 Minimum skylight fenestration area*, is hereby deleted and replaced with the following:~~

~~**C402.4.2 Minimum area of natural lighting.** A minimum skylight area of three percent of the roof area shall be provided for all roofs.~~

~~Exception: Roof areas designated for solar ready zones shall not be included in roof area calculation.~~

13. **C403.2 System design.** Mechanical systems shall be designed to comply with Sections C403.2.1 through ~~403.2.3~~ C403.2.4. Where elements of a building's mechanical systems are addressed in Sections C403 through C403.14, such elements shall comply with the applicable provisions of those sections.

14. Section C403.2.4 Space heating equipment is added as follows:

C403.2.4 Space heating equipment. Fossil-fuel warm air furnaces appliances and electric resistance space heating equipment shall not be permitted for space heating in new construction.

4. Heat pump efficiencies:

- a. Ductless System
 1. 14.3 SEER2;
 2. 7.5 HSPF2; or
 3. EnergyStar Cold Climate certified
- b. Ducted System
 1. 15.2 SEER2;
 2. 9 HSPF2; or
 3. EnergyStar Cold Climate certified

Exceptions:

1. *Emergency backup.* Where it is required by an applicable law or regulation to provide space heating with an emergency power system or a standby power system.
2. *Certain make-up air systems.* Electric resistance in make-up air systems where energy recovery ventilation is prohibited by the International Mechanical Code.
3. *Supplementary heat.* Electric resistance and natural gas/ propane heat used for supplementary heat in accordance with Section C403.4.1.1
4. *Electric resistance budget.* In addition to any exceptions in this section, Up to 5 W of electric resistance space heating per square foot of conditioned floor area in the building, not including supplementary heat.
5. *Integrated units.* Electric resistance heating elements, natural gas, propane supplemental heating integrated into heat pump equipment.
6. *Heated plenums.* Electric resistance in heated plenums.
7. *Temporary systems.* Temporary electric resistance heating systems are permitted where serving future tenant spaces that are unfinished and unoccupied, provided that the heating equipment is sized and controlled to achieve interior space temperatures no higher than needed to prevent freezing.
8. *Freeze protection.* Electric resistance in heating systems intended for freeze protection.
9. *Outdoor systems.* Equipment used for outdoor heating.
10. *Specific conditions.* Portions of buildings that require fossil fuel or electric resistance space heating for specific conditions approved by the Building Official for research, health care, process or other specific needs that cannot

practicably be served by heat pump or other space heating systems. This does not constitute a blanket exception for any occupancy type.

11. Replacements. Replacement fuel-fired appliances.
 12. Backup heat. For back up heat to operate when the heat pump cannot adequately heat the space/buildings due to extreme cold weather.
 13. Where cfm/sq. ft. ventilation requirements result in conditions where the Building Official determines that space heating requirements cannot reasonably be met without combustion space heating systems.
14. ~~Section C403.3.2 HVAC equipment performance requirements, is hereby deleted in its entirety and replaced~~ amended by adding the following at the beginning of the section with remainder of section to remain to read as follows:

C403.3.2 When HVAC fuel fired equipment is permitted to be installed, equipment shall meet the minimum efficiency requirements of Tables C403.3.2(1) through C403.3.2(16) when tested and rated in accordance with the applicable test procedure. Plate-type liquid-to-liquid heat exchangers shall meet the minimum requirements of AHRI 400. The efficiency shall be verified through certification under an approved certification program or, where a certification program does not exist, the equipment efficiency ratings shall be supported by data furnished by the manufacturer. Where multiple rating conditions or performance requirements are provided, the equipment shall satisfy all stated requirements. Where components, such as indoor or outdoor coils, from different manufacturers are used, calculations and supporting data shall be furnished by the designer that demonstrates that the combined efficiency of the specified components meets the requirements herein.

~~HVAC/fuel fired equipment performance requirements. Unless built all electric, all new combustion equipment shall comply with the more efficient HVAC equipment performance of Sections C406.2, C406.2.3, and C406.2.4 and the additional electric infrastructure requirements in Section C405.14. A mechanical compliance certificate demonstrating compliance with section C406.2.3 and/or C406.2.4 shall be required for all HVAC, fuel fired and Service Water Heating equipment.~~

~~The efficiency shall be verified through certification under an approved certification program or, where a certification program does not exist, the equipment efficiency ratings shall be supported by data furnished by the manufacturer. Where multiple rating conditions or performance requirements are provided, the equipment shall satisfy all stated requirements. Where components, such as indoor or outdoor coils, from different manufacturers are used, calculations and supporting data shall be furnished by the designer that demonstrates that the combined efficiency of the specified components meets the requirements herein. (Tables C403.2.(1) through (16) are expressly retained and remain applicable to HVAC equipment performance.)~~

~~Exceptions:~~

- ~~1. Factory, laboratory, and high hazard occupancy combustion equipment, except for HVAC and domestic water heating.~~
- ~~2. Commercial Kitchens.~~

~~3. — Other combustion equipment approved by the Building Official based on demonstration by the applicant that compliance with this section is not feasible and the equipment proposed is the most efficient appliance reasonably available.~~

16. *Section C403.4.1 Thermostatic controls*, is hereby deleted and replaced with the following:

C403.4.1 Thermostatic controls. The supply of heating and cooling energy to each *zone* shall be controlled by individual thermostatic controls capable of responding to temperature within the *zone*. Where humidification or dehumidification or both is provided, no fewer than one humidity control device shall be provided for each humidity control system. Occupancy sensors shall be provided on the thermostat to setback in accordance with C403.4.2.1

Exception: Independent perimeter systems that are designed to offset only building envelope heat losses, gains or both serving one or more perimeter *zones* also served by an interior system provided that both of the following conditions are met:

1. The perimeter system includes not fewer than one thermostatic control *zone* for each building exposure having exterior walls facing only one orientation (within ± 45 degrees) (0.8 rad) for more than 50 contiguous feet (15 240 mm).
2. The perimeter system heating and cooling supply is controlled by thermostats located within the *zones* served by the system.

17. *Section C403.12.1 Duct and plenum insulation and sealing*, is hereby deleted and replaced with the following:

C403.12.1 Duct and plenum insulation and sealing. All supply and return air ducts and plenums shall be insulated with not less than R-12. Ducts, air handlers and filter boxes shall be sealed. Joints and seams shall comply with Section 603.9 of the International Mechanical Code.

18. *Section C403.12.3 Piping insulation*, is hereby amended to read as follows:

C403.12.3 Piping insulation. Piping serving as part of a heating or cooling system shall be thermally insulated to R-5.

19. *Section C404.4 Insulation of piping*, is hereby amended to read as follows:

C404.4 Insulation of piping. Piping from a water heater to the termination of the heated water fixture supply pipe shall be insulated to R-3. On both the inlet and outlet piping of a storage water heater or heated water storage tank, the piping to a heat trap or the first 8 feet (2438 mm) of piping, whichever is less, shall be insulated. Piping that is heat traced shall be insulated to R-3 or the heat trace manufacturer's instructions.

20. *Section C404.10 Water heating equipment* is added as follows:

C404.10 Water heating equipment. Fossil fuel and electric resistance instantaneous and storage water heaters shall not be used to provide hot water in new construction.

Exceptions:

1. *Emergency backup.* Where it is required by an applicable law or regulation to provide water heating with an emergency power system or a standby power system.
2. *Integrated units.* Resistance heating elements integrated into heat pump water heating equipment.
3. *Recirculation loops.* Electric resistance elements used for recirculation loop temperature maintenance.
4. *Small systems.* Electric storage water heaters with a rated water storage volume no greater than 20 gallons.
5. *Point-of-use systems.* Instantaneous electric water heaters located within 10 feet of the point of use.
6. *Renewable electricity.* Electric resistance equipment where not less than 100 percent of the annual service water-heating requirement is provided by an *on-site renewable energy system* not used to meet any other provision of this code.
7. *Renewable or waste thermal energy.* Electric resistance storage water heating equipment in *buildings* where not less than 75% of the annual service water heating requirement is met by a solar thermal system or other renewable thermal system.
8. *High-temperature requirements.* Water heating systems that serve end-uses or have a storage requirement that necessitates a water temperature of 141°F (55°C) or hotter.
9. *Electric resistance budget.* In addition to any exceptions in this section, a budget of 24 kW plus 0.1 watts per square foot of building area of electric resistance service water heating capacity per building.
10. *Commercial kitchens.* Electric booster-heaters serving commercial dishwashers, commercial food service equipment, and other approved process equipment that require supply water temperatures of 120°F (49°C) or higher.
11. *Replacements.* Replacement of gas-fired storage water heaters or instantaneous water heaters.

21. Section C405.2.1 Occupant sensor controls, is hereby amended to read as follows:

C405.2.1 Occupant sensor controls. Occupant *sensor controls* shall be installed to control lighting.

22. Section C405.2.2 Time-switch controls, is hereby deleted in its entirety.

23. Section C405.2.2.1 Time-switch control function, is hereby deleted in its entirety.

24. *Section C405.2.3 Light-reduction controls*, is renumbered to C405.2.2.
25. *Section C405.2.3.1 Light-reduction function*, is renumbered to C405.2.2.1.
26. *Section C405.2.4 Daylight-responsive controls*, is renumbered to C405.2.3.
27. *Section C405.2.4.1 Daylight-responsive control function*, is renumbered to C405.2.3.1.
28. *Section C405.2.4.2 Sidelit daylight zone*, is renumbered to C405.2.3.2.
29. *Section C405.2.4.3 Toplit daylight zone*, is renumbered to C405.2.3.3.
30. *Section C405.2.4.4 Atriums*, is renumbered to C405.2.3.4.
31. *Section C405.2.5 Specific application controls*, is renumbered to C405.2.4.
32. *Section C405.2.6 Manual controls*, is renumbered to C405.2.5.
33. *Section C405.2.7 Exterior lighting controls*, is renumber to C405.2.6.
34. *Section C405.2.7.1 Daylight shut off*, is renumbered to C405.2.6.1.
35. *Section C405.2.7.2 Building façade and landscape lighting*, is renumbered to C405.2.6.2.
36. *Section C405.2.7.3 Lighting setback*, is renumbered to C405.2.6.3.
37. *Section C405.2.7.4 Exterior time-switch control function*, is renumbered to C405.2.6.4.
38. *Section C405.2.8 Parking garage lighting control*, is renumbered to C405.2.7.
39. *Section C405.4.3 Gas lighting*, is hereby amended to read as follows:

C405.4.3 Gas lighting. Gas-fired lighting appliances shall not be permitted.

40. A new *Section C405.13 Electric vehicle charging infrastructure for new construction and building addition of 25% or more of original square footage*, is hereby added to read as follows:

Section C405.13.1 Electric vehicle charging infrastructure for new construction and building addition of 25% or more of original square footage. Electric vehicle charging shall be provided and installed in accordance with this section, National Electrical Code (NFPA 70), and Section 17.20.170 of the Louisville Municipal Code. ~~When parking spaces are added or modified~~

~~without an increase in building floor area, only the new parking spaces are subject to this requirement.~~ All *EVSE Installed*, *EV Ready* and *EV Capable* spaces are to be included in the calculation for the number of minimum vehicle spaces required, as provided by the applicable article of the Louisville Zoning Code.

Section C405.13.2 Identification. The circuit breakers or circuit breaker spaces reserved for the *EVSE Installed*, *EV Ready*, and *EV Capable* spaces shall be clearly identified in the panelboard directory. The conduit for electric vehicle capable spaces shall be clearly identified at both the panelboard and the termination point at the parking space.

40. A new *Section C405.14 Additional electric infrastructure*, is hereby added to read as follows:

Section C405.14 Additional electric infrastructure. All *combustion equipment* and end-uses shall be installed in accordance with this section.

C405.14.1 Electric infrastructure for dwelling and sleeping units. *Combustion equipment* and end-uses serving individual dwelling units or sleeping units shall comply with Section R404.5.

C405.14.2 Combustion equipment. *Combustion equipment* shall be provided with conduit that is continuous between a junction box located within 3 feet (914 mm) of the appliance or equipment and an electrical panel. The junction box, conduit and bus bar in the electrical panel shall be rated and sized to accommodate a branch circuit with sufficient capacity for an equivalent electric appliance, equipment or end use with an equivalent equipment capacity. The electrical junction box and electrical panel shall have labels stating, "For Future Electric Equipment".

Exception: Industrial and manufacturing uses are exempt from Section C405.14.

41. *Section C502.1.1 General*, is hereby amended to read as follows:

Additions to an existing building, building system or portion thereof shall conform to the provisions of Section C401.2.4 as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. Additions shall not create unsafe or hazardous condition or overload existing building systems. An addition shall be deemed to comply with this code if the addition alone complies or if the existing building and addition comply with this code as a single building.

42. *Section C503.1 General* Exception 3 is deleted in its entirety.

43. *Section C503.2 Building Envelope* is amended with exception remaining to read as follows:

New building envelope assemblies that are part of the alteration shall comply with Sections C402.1 through C402.5. Existing ceilings, roofs, all wall types, or floors exposed during construction shall comply with Table C402.1.3.

44. *Section C505.1 General*, is hereby amended to read as follows:

C505.1 General. Where the use in a space changes from one use in Table C405.3.2(1) or C405.3.2(2) to another use in Table C405.3.2(1) or C405.3.2(2), the installed lighting wattage shall comply with Section C405.3. Where the space undergoing a change in occupancy or use is in a building with a fenestration area that exceeds the limitations of Section C402.4.1, the space is exempt from Section C402.4.1 provided that there is not an increase in fenestration area.

Exception: Egress doors with fenestration are allowed to bring total fenestration percentages over the allowed maximum amount of vertical fenestration.

APPENDIX PT MODELING TO A PERFORMANCE TARGET

PT101 Scope. This section establishes criteria for demonstrating compliance with a performance target, and is required for new hotels (occupancy R-1), multifamily (occupancy R-2), offices, primary and secondary schools, and warehouses. All end use load components within and associated with the building and their building sites shall be modeled.

PT102 Mandatory requirements. The requirements in this section are mandatory requirements and shall be required in addition to the provisions of ASHRAE 90.1 Appendix G.

PT103 Performance target. Projects of the types listed in Table PT103 shall demonstrate that the proposed design reaches a fixed energy use intensity (EUI) less than or equal to the values in Table PT103, calculated utilizing the energy modeling procedures of Appendix G of ASHRAE 90.1. For *buildings* with multiple occupancy types, the modeled performance target shall be a weighted average of the floor area of each occupancy type.

Exception: Energy used for electric vehicle charging, data centers, and process loads shall be excluded from compliance modeling.

**TABLE PT103
PERFORMANCE TARGETS**

BUILDING TYPE	PERFORMANCE TARGET (kBTU/ft ²)
---------------	--

Hotel (Occupancy R-1)	32
Multifamily (Occupancy R-2)	32
Office, small (≥ 0 - 5,000 ft ²)	19
Office, medium (5,000 – 50,000 ft ²)	23
Office, large (>50,000 ft ²)	28
School, primary	34
School, secondary	31
Warehouse	11

PT104 Renewable Energy. On-site renewable energy generated by a system installed as part of this project that is used by the building shall be subtracted from the proposed design energy consumption prior to calculating the proposed building performance.

PT105 Performance documentation. Documentation to verify compliance with this section shall be provided to the code official.

PT105.1 Projected compliance report. Permit submittals shall include a report documenting the proposed design is projected to meet the EUI target. The compliance report shall include the following specific information beyond the information required in ASHRAE 90.1 Appendix G:

1. Address of the building.
2. An inspection checklist documenting the building component characteristics of the proposed design.
3. Name of individual completing the report.
4. Name and version of compliance software tool.
5. Documentation of the reduction in energy use associated with on-site energy.

PT105.2 Construction plan requirements. Construction plans shall depict all component characteristics of the proposed design utilized for the EUI in accordance with ASHRAE 90.1 Appendix G.

PT105.3 Measured performance report. Projects shall demonstrate compliance with this code by documenting that the building has achieved the EUI performance calculated based on 12 months of metered energy use after occupancy.

PT105.3.1 Demonstration of operating energy use. Metered energy data demonstrating compliance with the EUI target shall be reported to the

~~building official using Energy Star Portfolio Manager and adjusted for the percentage of floor area occupied. While at least 75 percent occupied, the building shall operate at or below its assigned energy use target established in Section PT103 for any recording period of 12 consecutive months that is completed within three years of the date of the Certificate of Occupancy. The owner shall notify the building official when this 12-month period has been successfully completed.~~

~~**PT106 Energy metering and monitoring.** All projects must install submetering or monitoring capabilities to support building energy performance analysis. The project must include capabilities to store and access a 24-month continuous data set on an ongoing basis.~~

~~**PT106.1 End-use monitoring.** Measurement devices shall be installed in new *buildings* to monitor the electric energy use of each of the following separately:~~

- ~~1. Total electric energy.~~
- ~~2. HVAC systems energy use.~~
- ~~3. Interior lighting.~~
- ~~4. Exterior lighting.~~
- ~~5. Receptacle circuits.~~
- ~~6. Data centers representing over 10 percent of total building load or 5 percent of building floor area.~~
- ~~7. Other process loads that represent 10 percent or more of total building energy use based on building energy use modeling.~~

~~**PT106.2 Independent metering.** The following items shall be independently metered. Individual meters used to comply with this section may not serve multiple *buildings*.~~

- ~~1. All fuel sources serving the building.~~
- ~~2. Energy production from on-site renewable energy systems.~~
- ~~3. Electric vehicle (EV) supply equipment.~~
- ~~4. Data centers representing over 10 percent of total building load or 5 percent of building floor area.~~
- ~~5. Other process loads that represent 10 percent or more of total building energy use based on building energy use modeling.~~
- ~~6. Individual tenant energy loads.~~

45. *Section R101.1 Title*, is amended to insert "the City of Louisville" so the section will read:

R101.1 Title. These regulations shall be known as the Energy Conservation Code of the City of Louisville and shall be cited as such. It is referred to herein as "this code."

46. Section R103.2 *Information on construction documents*, is amended to read as follows:

R103.2 Information on construction documents. Construction documents shall be drawn to scale upon suitable material. Electronic media documented are permitted to be submitted when *approved* by the *code official*. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the building, systems and equipment herein governed. Details shall include the following as applicable:

1. Energy compliance path.
2. Insulation materials and their *R*-values
3. Fenestration *U*-factor and solar heat gain coefficients (SHGCs).
4. Area-weighted *U*-factor and solar heat gain coefficient (SHGC) calculations.
5. Mechanical system design criteria.
6. Mechanical and service water heating systems and equipment types, sizes, fuel source and efficiencies.
7. Equipment and system controls.
8. Duct sealing, duct and pipe insulation and location.
9. Air sealing detail.
10. Location of pathways for routing of raceways or cable from the solar ready zone to the electrical service panel.

47. Section R202 *General Definitions*, is hereby amended by adding, in alphabetical order, the following definitions:

All-Electric Building: A building that contains no combustion equipment, ~~or plumbing or piping for combustion equipment, installed within the building or building site.~~

Combustion Equipment: Any equipment or appliance used for space heating, service water heating, cooking, clothes drying and/or lighting that uses fuel gas or fuel oil.

~~*Electric Vehicle (EV)*: A vehicle registered for on-road use, primarily powered by an electric motor that draws current from a rechargeable storage source that is charged by being plugged into an electrical current source.~~

~~*Electric Vehicle Supply Equipment (EVSE)*: The electrical conductors and associated equipment external to the electric vehicle that provide a connection between the premises wiring and the electric vehicle to provide electric vehicle charging.~~

~~*Electric Vehicle Capable Space:* A designated parking space that is provided with conduit sized and rated for a minimum 40-amp, 208/240 Volt dedicated branch circuit and shall be no less than 1" in size. Conduit must be continuous from the future or existing electrical panel board or switchboard location(s) and end at a junction box or receptacle located within close proximity of the parking space. The electrical panel serving the parking space shall have sufficient capacity and physical space for a dual pole, 40-amp breaker. The conduit shall be sealed at the junction or outlet box that is capped off, with the conduit sealed and the cap labeled as "For future electric vehicle charging".~~

~~*Electric Vehicle Ready Space:* A designated parking space that is provided with a dedicated branch circuit with wiring capable of supporting a minimum 40-ampere, 208/240 Volt circuit that terminates at a receptacle, plug, junction box, or an installed electric vehicle supply equipment within close proximity of the parking space. There shall be adequate reserved space in an electrical panel board or switchboard to meet the electric vehicle requirements.~~

~~Residential Building. For this code, includes detached one- and two-family dwellings and multiple single-family dwellings (townhouses) and R-3 and R-4 buildings three stories or less in height above grade plane.~~

48. *Section R401.2 Application*, is hereby deleted and replaced with the following:

R401.2 Application. New Residential buildings shall be built using appendix RB and RC and shall be built all-electric unless the fuel gas options of R403.7 and additional electric infrastructure requirements of R404.5 are met. ~~All residential buildings shall comply with the R401.2.1 City of Louisville's Prescriptive Compliance or R406 Energy Rating Index with a maximum rating index of 50 before the installation of solar panels~~

Exceptions:

1. New residential buildings certified through the Passive House Institute US, Inc. (PHIUS) program
2. Additions shall comply with R401.2.1 and Chapter 5
3. ~~Additions, a~~Alterations, repairs and changes of occupancy to existing buildings complying with Chapter 5.

49. *Section R401.2.1 Prescriptive Compliance Option*, is hereby deleted and replaced with the following:

R401.2.1 City of Louisville's Prescriptive Compliance. The City of Louisville's Prescriptive compliance requires compliance with Sections R401 through R404.

50. *Section R401.2.2 Total Building Performance Option*, is hereby deleted in its entirety.

51. *Section R401.2.4 Tropical Climate Region*, is hereby deleted in its entirety.

52. *Section R401.2.5 Additional Energy Efficiency*, is hereby amended to read as follows:

Section R401.2.5 Additional Energy Efficiency. Building shall comply with one of the additional efficiency options and shall be installed in according to Section R408.2.

53. A new *Section R401.4 Mandatory requirements for residential buildings*, is hereby added to read as follows:

R401.4 Mandatory requirements for residential buildings. Residential building must comply with the following sections from the 2021 International Energy Conservation Code found in Table R401.4 and Section R401.2.

Table R401.34
Mandatory requirements for residential buildings

Title	IECC Section
Vapor retarder	R402.1.1
Eave baffle	R402.2.3
Access hatches and doors	R402.2.4.1
Crawl space wall insulation	R402.4.1.2
Maximum fenestration U-factor and SHGC	R402.5
Mechanical Controls	R403.1
Ducts	R403.3 except R403.3.2, R403.3.3, and R403.6
Mechanical system piping insulation	R403.4
Heated water circulation and temperature maintenance systems	R403.5.1
Drain Water heat recovery units	R403.5.3
Mechanical ventilation	R403.6 including E403.6.1
Equipment sizing and efficiency rating	R403.7
Systems serving multiple dwelling units	R403.8
Snow melt and ice systems	R403.9
Energy consumption of pools and spas	R403.10
Portable spas	R403.11
Residential pools and permanent residential spas	R403.12
Lighting equipment	R404.1
Interior lighting controls	R404.2

54. *Section R402.1 General*, is hereby amended to read as follows:

R402.1 General. The building thermal envelope shall comply with the requirements of Section R402.1.1 and R402.1.2.

55. Section R402.1.2 *Insulation and fenestration*, is hereby deleted and replaced with the following:

R402.1.2 Insulation and fenestration. ~~New and replacement Assemblies shall have R-value of insulation materials equal to or greater than that specified in Table R402.1.2 unless an alternative path is specified while using HERS energy rating index of 50.~~

Exception: New Construction complying with R401.2 or exception 1

56. Section R402.1.2.1 *Fenestration* is hereby added to read as following:

R402.1.2.1 Fenestration. New and replacement assemblies shall not exceed the value specified in Table R402.1.2.

Exception: New Construction complying with R401.2 or exception 1

Table R402.1.2
Average Insulation and Fenestration Requirements by Component

Roof	R-60
Above grade walls	R-21
Below grade walls	R-21
Floors	R-38
Non heated slab on grade	R-10 for 4ft
Heated slab on grade	R-15 for 4 ft + R-5 under full slab
Fenestration U-Factor	.30
Fenestration SHGC	.33
Skylight U-Factor	.50
Skylight SHGC	.40
<u>Hot Water Pipes</u>	<u>R-5</u>
<u>Warm Air Ducts</u>	<u>R-8</u>

55. Section R402.1.5 Total UA alternative, is hereby deleted in its entirety.

56. Section R402.3.3 Glazed fenestration exemption, is hereby amended to read as follows:

R402.3.3 Glazed fenestration exemption. Not greater than 15 square feet (1.4 m²) of glazed fenestration per dwelling unit shall be exempt from the U-factor and SHGC requirements in Section R402.1.2.

57. *Section R402.4.1.2 Testing*, is hereby deleted and replaced to read as follows:

Section R402.4.1.2 Testing. All new buildings or dwelling units that are heated or cooled, and additions over 500 square feet shall be tested for air leakage.

58. *Section R402.5 Maximum fenestration U-factor and SHGC*, is hereby deleted and replaced with the following:

Section R402.5 Maximum fenestration U-factor and SHGC. The maximum U-factor and solar heat gain coefficient (SHGC) for fenestration shall not be required in storm shelters complying with ICC 500.

59. *Section R403.3.1 Ducts located outside conditioned space*, is hereby deleted and replaced with the following:

R403.3.1 Ducts located outside conditioned space. All supply and return ducts shall be insulated to a minimum R-8 if located outside a conditioned space.

60. *Section R403.5.2 Hot water pipe insulation*, is hereby deleted and replaced with the following:

R403.5.2 Hot water pipe insulation. All service hot water piping shall be insulated to a minimum R-5.

~~61. *Section R403.6.1 Heat and recovery ventilation*, is hereby deleted and replaced in its entirety and the following is hereby added in lieu thereof:~~

~~**R403.5.2 Heat and recovery ventilation.** All new buildings and additions over 500 square feet shall be provided with a heat recovery or energy recovery ventilation system. The system shall be balanced with a minimum sensible heat recovery efficiency of 65 percent at 32°F (0°C) at a flow greater than or equal to the design airflow.~~

62. *Section R403.7 Equipment sizing and efficiency rating*, is hereby deleted and replaced with the following:

R403.7 Equipment sizing and efficiency rating. All new buildings and additions greater than 500 square feet with heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies. In addition to complying with Sec. R404.6 Additional Electric Infrastructure, new and replacement electrical heating and cooling equipment shall have an efficiency rating equal to or greater than the minimum required by federal law for the geographic location where the equipment is installed. New gas heating equipment shall comply with the following efficiencies:

1. Gas furnaces shall have a minimum of 96% efficiency.
2. Gas boilers shall have a minimum of 90% AFUE.
3. On demand water heaters shall have a greater than .92 uniform energy factor.
4. Heat pump efficiencies:
 - a. Ductless System
 1. 14.3 SEER2;
 2. 7.5 HSPF2; or
 3. EnergyStar Cold Climate certified
 - b. Ducted System
 1. 15.2 SEER2;
 2. 9 HSPF2; or
 3. EnergyStar Cold Climate certified

Exception: Solid fuel stoves/gas fireplaces, outdoor fire pits, gas stoves and ovens.

63. *Section R404.1.1 Fuel gas lighting equipment, is hereby amended to read as follows:*

R404.1.1 Fuel gas lighting equipment. Fuel gas lighting systems shall not be installed.

64. A new *Section R404.4 Electric vehicle charging infrastructure for new construction and building addition of 50% or more of original square footage*, is hereby added to read as follows:

Section R404.4 Electric vehicle charging infrastructure for new construction and building addition of 50% or more of original square footage. Electric infrastructure for the current and future charging of *electric vehicles* shall be installed in accordance with this section per Section 17.20.170 of the Louisville Municipal Code. *EV ready spaces and EV capable spaces* are permitted to be counted toward meeting minimum parking requirements.

R404.4.1 One- and two- family dwellings and townhouses. One- and two-family dwellings and townhouses with a dedicated attached or detached garage or on-site parking spaces shall be provided with electric vehicle charging in accordance with Section 17.20.170 of the Louisville Municipal Code.

R404.4.1.1 Minimum EV Ready infrastructure. Minimum EV Ready Space infrastructure shall require the following:

1. Installation of conductors:
 - a. Conductors shall be installed of sufficient size to accommodate a minimum 240VAC 40Amp branch circuit to each parking space where required.
 - b. Conductors shall terminate in either a receptacle, plug, junction or outlet box, or an *EVSE* installed in the parking space.

2. The electrical panel directory shall designate the branch circuit as “EV Ready” and the junction box or receptacle shall be labelled “EV Ready.”

R404.4.1.2 Construction documents. Construction documents shall graphically indicate and label all EV ready spaces and associated termination locations. For all Townhouses and one- and two-family dwellings with an electrical utility service of 200 Amps or greater, a panelboard schedule shall be provided indicating the EV Ready circuit breaker space(s) and the circuit designation(s).

R404.4.2 Group R occupancies. Group-R occupancies (~~R-2~~, R-3, and R-4 buildings three stories and less) with three or more dwelling units and/or sleeping units shall be provided with electric vehicle charging in accordance with Section 17.20.170 of the Louisville Municipal Code.

Electric vehicle charging shall be provided and installed in accordance with this section and the National Electrical Code (NFPA 70). When parking spaces are added or modified without an increase in building floor area, only the new parking spaces are subject to this requirement.

65. A new *Section R404.5 Additional electric infrastructure*, is hereby added to read as follows:

R404.5 Additional electric infrastructure. *Combustion equipment* shall be installed in accordance with this section.

R404.5.1 Combustion equipment and end-uses. *Combustion equipment* shall be provided with a dedicated, appropriately phased circuit that shall have a minimum amperage requirement for a comparable electric appliance, equipment or end use, an electrical receptacle or junction box that is connected to the electric panel, and conductors of adequate capacity within 6 feet (1829 mm) of the appliance or equipment.

Each such circuit shall be accessible with no obstructions. A reserved circuit breaker space shall be installed in the electrical panel adjacent to the circuit breaker for the branch circuit and labeled for each circuit. Both ends of the unused conductor or conduit shall be labeled “For Future Electric Equipment” and be electrically isolated.

66. *Section R405 Total building performance*, is deleted in its entirety.

67. *Section R406.3 Building thermal envelope*, is hereby deleted in its entirety and replaced with the following:

R406.3 Building thermal envelope. ~~Building and portions thereof shall comply with Table R406.3. The building thermal envelope shall be greater or equal to the levels of efficiency and SHGC in Table R406.3.~~

**Table R406.3
Average of the Minimum Insulation and Maximum Fenestration Requirements by
Component**

Roof	R-60
Above grade walls	R-21
Below grade walls	R-21
Floors	R-38
Non heated slab on grade	R-10 for 4ft
Heated slab on grade	R-15 for 4 ft + R-5 under full slab
Fenestration U-Factor	.30
Fenestration SHGC	.33
Skylight U-Factor	.50
Skylight SHGC	.40
<u>Heated Water Pipes</u>	<u>R-5</u>
<u>Heated air Ducts</u>	<u>R-8</u>

68. *Section R406.3.1 On-site renewables are not included*, is deleted in its entirety.
69. *Section R406.3.2 On-site renewables are included*, is deleted in its entirety.
70. *Section ~~406.3.2~~ R407 Tropical Climate Region Compliance Path*, is deleted in its entirety.
71. *Section R502.1.1 General*, is hereby amended to read as follows:

Additions to an existing building, building system or portion thereof shall conform to the provisions of R401.2.1 as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. Additions shall not create unsafe or hazardous condition or overload existing building systems. An addition shall be deemed to comply with this code where the addition alone complies, where the existing building and addition comply with this code as a single building, or where the building with the addition does not use more energy than the existing building. Additions shall be in accordance with Section R502.2 or R502.3.

72. *Section R503.1.1 Building Envelope* is amended to read as follows:

Building envelope assemblies that are part of the alteration shall comply with Section R401.2.1

Section R503.1.1 Building envelope Exception 2 is deleted in its entirety and replaced with the following.

2. Section R402.4.1.2 Testing

73. *Section R505.1 General* is hereby amended to remove the exception.

74. *Section R505.1.1 Unconditioned space*, is hereby deleted and replaced with the following:

R505.1.1 Unconditioned space. Any unconditioned or low-energy space that is altered to become a conditioned space shall comply with Section R503.

75. RC102.1 General is amended to read as follows.

RC102.1 General. New residential buildings shall comply with Sections RC102.2 through RC102.9.

76. RC102.2 Energy Rating Index zero energy score is amended to read as follows.

RC102.2 Energy Rating Index zero energy score.

Compliance with this section requires that the rated design be shown to have a Home Energy Rating System (HERS) score of 47 before solar and 0 with solar when compared to the Energy Rating Index (ERI) reference design determined in accordance with RESNET/ICC 301 for both of the following:

1. ERI value not including on-site power production (OPP) calculated in accordance with RESNET/ICC 301.
2. ERI value including on-site power production calculated in accordance with RESNET/ICC 301 with the OPP in Equation 4.1.2 of RESNET/ICC 301 adjusted in accordance with Equation RC-1.

Adjusted OPP = OPP + CREF + REPC (Equation RC-1)

where:

CREF = Community Renewable Energy Facility power production—the yearly energy, in kilowatt hour equivalent (kWheq), contracted from a community renewable energy facility that is qualified under applicable state and local utility statutes and rules, and that allocates bill credits to the rated home.

REPC = Renewable Energy Purchase Contract power production—the yearly energy, in kilowatt hour equivalent (kWheq), contracted from an energy facility that generates energy with photovoltaic, solar thermal, geothermal energy or wind systems, and that is demonstrated by an energy purchase contract or lease with a duration of not less than 15 years.

RC102.2.1 HERS Score. Buildings shall comply with the scores in Table RC102.2.1.

Table RC102.2.1.

<u>HERS SCORE NOT INCLUDING OPP</u>	<u>HERS SCORE INCLUDING OPP</u>
<u>47</u>	<u>0</u>

76. RC102.3 through RC102.9 are added to Appendix RC to read as follows.

RC102.3 Mandatory Sections. All projects shall comply with all sections within Table RC102.3.

Table RC102.3
Mandatory requirements for residential buildings

<u>Title</u>	<u>IECC Section</u>
<u>Vapor retarder</u>	<u>R402.1.1</u>
<u>Eave baffle</u>	<u>R402.2.3</u>
<u>Access hatches and doors</u>	<u>R402.2.4.1</u>
<u>Crawl space wall insulation</u>	<u>R402.4.1.2</u>
<u>Maximum fenestration U-factor and SHGC</u>	<u>R402.5</u>
<u>Mechanical Controls</u>	<u>R403.1</u>
<u>Ducts</u>	<u>R403.3 except R403.3.2, R403.3.3, and R403.6</u>
<u>Mechanical system piping insulation</u>	<u>R403.4</u>
<u>Heated water circulation and temperature maintenance systems</u>	<u>R403.5.1</u>
<u>Drain Water heat recovery units</u>	<u>R403.5.3</u>
<u>Mechanical ventilation</u>	<u>R403.6 including E403.6.1</u>
<u>Equipment sizing and efficiency rating</u>	<u>R403.7</u>
<u>Systems serving multiple dwelling units</u>	<u>R403.8</u>
<u>Snow melt and ice systems</u>	<u>R403.9</u>
<u>Energy consumption of pools and spas</u>	<u>R403.10</u>
<u>Portable spas</u>	<u>R403.11</u>
<u>Residential pools and permanent residential spas</u>	<u>R403.12</u>
<u>Lighting equipment</u>	<u>R404.1</u>
<u>Interior lighting controls</u>	<u>R404.2</u>

RC102.4 Building Envelope. The building thermal envelope shall be greater or equal to the levels of efficiency and SHGC in Table RC102.4.

Table RC102.4
Average of the Minimum Insulation and Maximum Fenestration Requirements by Component

<u>Roof</u>	<u>R-60</u>
<u>Above grade walls</u>	<u>R-21</u>
<u>Below grade walls</u>	<u>R-21</u>
<u>Floors</u>	<u>R-38</u>
<u>Non heated slab on grade</u>	<u>R-10 for 4ft</u>
<u>Heated slab on grade</u>	<u>R-15 for 4 ft + R-5 under full slab</u>
<u>Fenestration U-Factor</u>	<u>.30</u>
<u>Fenestration SHGC</u>	<u>.33</u>
<u>Skylight U-Factor</u>	<u>.50</u>
<u>Skylight SHGC</u>	<u>.40</u>

RC102.5 Verification by approved agency.

Verification of compliance with Section R102.4 as outlined in Sections of this appendix shall be completed by an approved third party. Verification of compliance with Section R102.3 shall be completed by the authority having jurisdiction or an approved third-party inspection agency in accordance with Section R105.4.

RC102.6 Documentation.

Documentation of the software used to determine the ERI and the parameters for the residential building shall be in accordance with Sections RC102.6.1 through RC102.6.4

RC102.6.1 Compliance software tools.

Software tools used for determining HERS shall be Approved Software Rating Tools in accordance with RESNET/ICC 301.

RC102.6.2 Compliance report.

Compliance software tools shall generate a report that documents that the home and the HERS score of the rated design complies with RC102. Compliance documentation shall be created for the proposed design and shall be submitted with the application for the building permit. Confirmed compliance documents of the built dwelling unit shall be created and submitted to the code official for review before a certificate of occupancy is issued. Compliance reports shall include information in accordance with Sections RC102.6.3 and RC102.6.4.

RC102.7 Additional documentation.

The code official shall be permitted to require the following documents:

1. Documentation of the building component characteristics of the ERI reference design.
2. A certification signed by the builder providing the building component characteristics of the rated design.
3. Documentation of the actual values used in the software calculations for the rated design.

RC102.8 Specific approval.

Performance analysis tools meeting the applicable subsections of Section RC102 shall be approved. Documentation demonstrating the approval of performance analysis tools in accordance with Section RC102 shall be provided.

RC102.9 Input values.

Where calculations require input values not specified by Sections RC 102, those input values shall be taken from RESNET/ICC 301.

**INTRODUCED, READ, PASSED ON FIRST READING, AND ORDERED
PUBLISHED** this _____ day of _____, 2024.

Christopher M. Leh, Mayor

ATTEST:

Meredyth Muth, City Clerk

APPROVED AS TO FORM:

Kelly PC, City Attorney

PASSED AND ADOPTED ON SECOND AND FINAL READING, this _____ day of _____, 2024.

Christopher M. Leh, Mayor

ATTEST:

Meredyth Muth, City Clerk