

**NOTICE OF PUBLIC HEARING
ORDINANCE No. 1884, SERIES 2024**

**AN ORDINANCE ADOPTING THE CITY OF LOUISVILLE FIRE HARDENING CODE
FOR STRUCTURES**

**INTRODUCED, READ, PASSED ON FIRST READING, AND ORDERED PUBLISHED
this 15th day of October 2024.**

Christopher M. Leh, Mayor

ATTEST:
Genny Kline, Interim City Clerk

APPROVED AS TO FORM:
Kelly, P.C., City Attorney

**PASSED AND ADOPTED ON SECOND AND FINAL READING, this 4th day of
November 2024.**

Christopher M. Leh, Mayor

ATTEST:
Genny Kline, Interim City Clerk

Published in the *Daily Camera* on November 10, 2024

Full copies available in the City Clerk's Office, 749 Main Street, Louisville CO 80027

Second Reading Amendments

Ordinance No. 1884, Series 2024 was revised by the removal of the following:

Sec. 15.70.030 Exemptions.

- B. Single Family Homes. Homes that are fully sprinklered with a min of a NPFA13-R system and are greater than 35 feet from any property line are exempt from the requirements of this Chapter.